General Specifications

EJA120E Differential Pressure Transmitter

DP harp

GS 01C31B03-01EN

The high performance draft range differential pressure transmitter EJA120E features single crystal silicon resonant sensor and is suitable to measure liquid, gas, or steam flow as well as liquid level, density and pressure. EJA120E outputs a 4 to 20 mA DC signal corresponding to the measured differential pressure.

Its accurate and stable sensor can also measure the static pressure which can be shown on the integral indicator or remotely monitored via BRAIN or HART communications. Other key features include quick response, remote set-up using communications and self-diagnostics. FOUNDATION Fieldbus and PROFIBUS PA protocol types are also available. All EJA-E series models in their standard configuration, with the exception of the Fieldbus and PROFIBUS types, are certified as complying with SIL 2 for safety requirement.

STANDARD SPECIFICATIONS

Refer to GS 01C31T02-01EN for Fieldbus communication type and GS 01C31T04-01EN for PROFIBUS PA communication type for the items marked with " \Diamond ."

□ SPAN AND RANGE LIMITS

Measurement Span/Range			kPa	inH2O (/D1)	mbar (/D3)	mmH2O (/D4)
Г		Span	0.1 to 1	0.4 to 4	1 to 10	10 to 100
	Range	-1 to 1	-4 to 4	-10 to 10	-100 to 100	

PERFORMANCE SPECIFICATIONS

Zero-based calibrated span, linear output, wetted parts material code S and silicone oil, unless otherwise mentioned.

For Fieldbus and PROFIBUS PA communication types, use calibrated range instead of span in the following specifications.

Specification Conformance

EJA-E series ensures specification conformance to at least $\pm 3\sigma.$

Reference Accuracy of Calibrated Span

(includes terminal-based linearity, hysteresis, and repeatability)

Measurem	ent span	E
Reference	X ≤ span	±0.2% of Span
accuracy	X > span	±(0.15+0.02 URL/span)% of Span
Х		0.4 kPa (1.6 inH2O)
URL (upper range limit)		1 kPa (4 inH2O)

[When /HAC is specified]

Measurem	ent span	E
Reference	X ≤ span	±0.09% of Span
accuracy	X > span	±(0.015+0.03 URL/span)% of Span
Х		0.4 kPa (1.6 inH2O)
URL (upper range limit)		1 kPa (4 inH2O)



Square Root Output Accuracy

The square root accuracy is a percent of flow span.

Output	Accuracy
50% or Greater	Same as reference accuracy
50% to Dropout point	Reference accuracy × 50 Square root output (%)

Ambient Temperature Effects per 28°C (50°F) Change

±(0.15% Span + 0.2% URL)

Power Supply Effects(Output signal code D and J) ± 0.005 % per Volt (from 21.6 to 32 V DC, 350 Ω)

Vibration Effects

Amplifier housing code 1 and 3: Less than 0.1% of URL when tested per the requirements of IEC60770-1 field or pipeline with high vibration level (10-60 Hz, 0.21 mm peak to peak displacement/60-2000 Hz 3 g) Amplifier housing code 2: Less than ±0.1% of URL when tested per the

requirements of IEC60770-1 field with general application or pipeline with low vibration level (10-60 Hz 0.15mm peak to peak displacement /60-500 Hz 2g)

Mounting Position Effects

Rotation in diaphragm plane has no effect. Tilting up to 90 degree will cause zero shift up to 0.4 kPa (1.6 inH₂O) which can be corrected by the zero adjustment.

Response Time (Differential pressure) "◊" 150 ms

When amplifier damping is set to zero and including dead time of 45 ms (nominal)



Yokogawa Electric Corporation 2-9-32, Nakacho, Musashino-shi, Tokyo, 180-8750 Japan Tel.: 81-422-52-5690 Fax.: 81-422-52-2018

FUNCTIONAL SPECIFICATIONS

Output "0"

Two wire 4 to 20 mA DC output with digital communications, linear or square root programmable. BRAIN or HART FSK protocol are superimposed on the 4 to 20 mA signal. Output range: 3.6 mA to 21.6 mA Output limits conforming to NAMUR NE43 can be

pre-set by option code Č2 or C3.

Failure Alarm (Output signal code D and J) Analog output status at CPU failure and hardware error:

Up-scale: 110%, 21.6 mA DC or more (standard) Down-scale: -5%, 3.2 mA DC or less

Damping Time Constant (1st order)

Amplifier damping time constant is adjustable from 0.00 to 100.00 s by software and added to response time

Note: For BRAIN protocol type, when amplifier software damping is set to less than 0.5 s, communication may occasionally be unavailble during the operation, especially while output changes dynamically. The default setting of damping ensures stable communication.

Update Period "0"

Differential pressure: 45 ms

Zero Adjustment Limits

Zero can be fully elevated or suppressed, within the lower and upper range limits of the capsule.

External Zero Adjustment

External zero is continuously adjustable with 0.01% incremental resolution of span. Re-range can be done locally using the digital indicator with rangesetting switch.

Integral Indicator (LCD display, optional) "0"

5-digit numerical display, 6-digit unit display and bar graph.

The indicator is configurable to display one or up to four of the following variables periodically.; Measured differential pressure, differential pressure in %, scaled differential pressure. See also "Factory Setting.

Self Diagnostics

CPU failure, hardware failure, configuration error, and over-range error for differential pressure, and capsule temperature.

User-configurable process high/low alarm for differential pressure is also available.

Signal Characterizer (Output signal code D and J) User-configurable 10-segment signal characterizer for 4 to 20 mA output.

SIL Certification

EJA-E series transmitters except Fieldbus and PROFIBUS PA communication types are certified in compliance with the following standards; IEC 61508: 2000; Part1 to Part 7 Functional Safety of Electrical/electronic/ programmable electronic related systems; SIL 2 capability for single transmitter use, SIL 3 capability for dual transmitter use.

NORMAL OPERATING CONDITION (Optional features or approval codes may affect limits.)

Ambient Temperature Limits -25 to 80°C (-13 to 176°F)

Process Temperature Limits -25 to 80°C (-13 to 176°F)

Ambient Humidity Limits 0 to 100% RH

Working Pressure Limits (Silicone oil) -50 to 50 kPa (-7.25 to 7.25 psi)

Supply & Load Requirements (Output signal code D and J. Optional features or approval codes may affect electrical requirements.)

With 24 V DC supply, up to a 550 Ω load can be used. See graph below.




Figure 1. Relationship Between Power Supply Voltage and External Load Resistance

Supply Voltage "0"

- 10.5 to 42 V DC for general use and flameproof type.
- 10.5 to 32 V DC for lightning protector
- (option code /A.)
- 10.5 to 30 V DC for intrinsically safe, type n, or nonincendive.

Minimum voltage limited at 16.6 V DC for digital communications, BRAIN and HART

Load (Output signal code D and J)

0 to 1290Ω for operation

250 to 600Ω for digital communication

Communication Requirements "0"

(Approval codes may affect electrical requirements.)

Communication Distance

Up to 2 km (1.25 miles) when using CEV polyethylene-insulated PVC-sheathed cables. Communication distance varies depending on type of cable used.

Load Capacitance

 $0.22 \ \mu F$ or less

Load Inductance 3.3 mH or less

Input Impedance of communicating device 10 k Ω or more at 2.4 kHz.

EMC Conformity Standards CE , C N200

EN61326-1 Class A, Table2 (For use in industrial locations) EN61326-2-3

EN61326-2-5 (for PROFIBUS only)

European Pressure Equipment Directive 97/23/EC Sound Engineering Practice (for all capsules)

Safety Requirement Standards

- EN61010-1
- Altitude of installation site: Max. 2,000 m above sea level
- Installation category: I
- Pollution degree: 2
- Indoor/Outdoor use

PHYSICAL SPECIFICATIONS

Wetted Parts Materials

Diaphragm, Cover Flange, Process Connector, Capsule Gasket, and Vent/Drain Plug Refer to "MODEL AND SUFFIX CODES."

Process Connector Gasket

PTFE Teflon

Fluorinated rubber for option code N2 and N3

Non-wetted Parts Materials

Bolting

B7 carbon steel, 316L SST or 660 SST

Housing

Low copper cast aluminum alloy with polyurethane, deep sea moss green paint (Munsell 0.6GY3.1/2.0 or its equivalent), or ASTM CF-8M Stainless Steel

Degrees of Protection

IP66/IP67, NEMA TYPE 4X

Cover O-rings

Buna-N, fluoro-rubber (optional)

Name plate and tag

316 SST

Fill Fluid

Silicone oil

Weight

[Installation code 7, 8 and 9] 3.7 kg (8.2 lb) without integral indicator, mounting bracket, and process connector. Add 1.5 kg (3.3lb) for Amplifier housing code 2.

Connections

Refer to "MODEL AND SUFFIX CODES." Process connection of cover flange: IEC61518

< Related Instruments>

Power Distributor: Refer to GS 01B04T01-02E or GS 01B04T02-02E

BRAIN TERMINAL: Refer to GS 01C00A11-00E

< Reference >

- DPharp EJA, FieldMate; Trademarks of Yokogawa Electric Corporation.
- Teflon; Trademark of E.I. DuPont de Nemours & Co.
- Hastelloy; Trademark of Haynes International Inc.
- HART; Trademark of the HART Communication Foundation.
- FOUNDATION Fieldbus; Tradmark of Fieldbus Foundation.
- PROFIBUS; Registered trademark of Profibus Nutzerorganisation e.v., Karlsruhe, Germany.
 Other company names and product names used in

this material are registered trademarks or trademarks of their respective owners.

■ MODEL AND SUFFIX CODES

Model	Suffix Codes	Description
EJA120E		Differential pressure transmitter
Output signal	-D -J -F -G	 4 to 20 mA DC with digital communication (HART 5/HART 7 protocol)^{*1} Digital communication (FOUNDATION Fieldbus protocol, refer to GS 01C31T02-01EN)
Measurement span (capsule)	E	
Wetted parts material *2	□	. Refer to "Wetted Parts Material" Table below.
Process connecti	ons 0 1 2 3 4 5	 with Rc1/4 female process connector with Rc1/2 female process connector with 1/4 NPT female process connector
Bolts and nuts ma	dteria J G C	. 316L SST
Installation	-7 -8 -9 -U	 Horizontal piping and right side high pressure Horizontal piping and left side high pressure
Amplifier housing	1 3 2	Cast aluminum alloy with corrosion resistance properties*3
Electrical connec	ion	 1/2 NPT female, two electrical connections without blind plugs M20 female, two electrical connections without blind plugs G1/2 female, two electrical connections and a blind plug^{*5} 1/2 NPT female, two electrical connections and a blind plug^{*5} M20 female, two electrical connections and a blind plug^{*5} G1/2 female, two electrical connections and a blind plug^{*5} G1/2 female, two electrical connections and a blind plug^{*5} G1/2 female, two electrical connections and a blind plug^{*5} G1/2 female, two electrical connections and a SUS316 blind plug 1/2 NPT female, two electrical connections and a SUS316 blind plug
Integral indicator	D E N	. Digital indicator with the range setting switch*7
Mounting bracket	► B D J K	 . 304 SST 2-inch pipe mounting, L type (for vertical piping) . 316 SST 2-inch pipe mounting, flat type (for horizontal piping) . 316 SST 2-inch pipe mounting, L type (for vertical piping)
Optional Codes		□/ Optional specification

The "▶" marks indicate the most typical selection for each specification.

HART 5 or HART 7 is selectable. Specify upon ordering. *1:

*2: A Users must consider the characteristics of selected wetted parts material and the influence of process fluids. The use of inappropriate materials can result in the leakage of corrosive process fluids and cause injury to personnel and/or damage to plant facilities. It is also possible that the diaphragm itself can be damaged and that material from the broken diaphragm and the fill fluid can contaminate the user's process fluids. Be very careful with highly corrosive process fluids such as hydrochloric acid, sulfuric acid, hydrogen sulfide, sodium

hypochlorite, and high-temperature steam (150°C [302°F] or above). Contact Yokogawa for detailed information of the wetted parts material.

*3: Not applicable for electrical connection code 0, 5, 7, 9 and A. Content rate of copper in the material is 0.03% or less and content rate of iron is 0.15% or less.

- *4: Not applicable for electrical connection code 0, 5, 7 and 9.
- *5: Material of a blind plug is aluminum alloy or 304 SST.
- *6: *7: Not applicable for output signal code G.
- Not applicable for output signal code F.

Table. Wetted Parts Materials

Wetted parts material code	Cover flange and process connector	Capsule	Capsule gasket	Drain/Vent plug
S #	ASTM CF-8M *1	Hastelloy C-276 *2 (Diaphragm) F316L SST (Others)	PTFE Teflon	316 SST

Cast version of 316 SST. Equivalent to SCS14A. Hastelloy C-276 or ASTM N10276.

*1: *2:

*3: 316L SST, F316L SST.

The '#'marks indicate the construction materials conform to NACE material recommendations per MR0175/ISO15156. Please refer to the latest standards for details. Selected materials also conform to NACE MR0103.

■ OPTIONAL SPECIFICATIONS (For Explosion Protected type) "◊"

Item	Description	Code
Factory Mutual (FM)	FM Explosionproof Approval ^{*1} Applicable Standard: FM3600, FM3615, FM3810, ANSI/NEMA 250 Explosionproof for Class I, Division 1, Groups B, C and D, Dust-ignitionproof for Class II/III, Division 1, Groups E, F and G, in Hazardous locations, indoors and outdoors (NEMA TYPE 4X) "FACTORY SEALED, CONDUIT SEAL NOT REQUIRED." Temperature class: T6, Amb. Temp.: -40 to 60°C (-40 to 140°F)	FF1
	 FM Intrinsically safe Approval ^{*1} Applicable Standard: FM3600, FM3610, FM3611, FM3810 Intrinsically Safe for Class I, Division 1, Groups A, B, C & D, Class II, Division 1, Groups E, F & G and Class III, Division 1, Class I, Zone 0, in Hazardous Locations, AEx ia IIC Nonincendive for Class I, Division 2, Groups A, B, C & D, Class II, Division. 2, Groups F & G, Class I, Zone 2, Group IIC, in Hazardous Locations Enclosure: "NEMA TYPE 4X", Temp. Class: T4, Amb. Temp.: –60 to 60°C (–75 to 140°F) Intrinsically Safe Apparatus Parameters [Groups A, B, C, D, E, F and G] Vmax=30 V, Imax=220 mA, Pmax=1 W, Ci=6 nF, Li=0 μH [Groups C, D, E, F and G] Vmax=30 V, Imax=225 mA, Pmax=1 W, Ci=6 nF, Li=0 μH 	FS1
	Combined FF1 and FS1 ^{*1}	FU1
ATEX	ATEX Flameproof Approval ^{*1} Applicable Standard: EN 60079-0:2009, EN 60079-1:2007, EN 60079-31:2009 Certificate: KEMA 07ATEX0109 X II 2G, 2D Ex d IIC T6T4 Gb, Ex tb IIIC T85°C Db IP6X Degree of protection: IP66/IP67 Amb. Temp. (Tamb) for gas-proof : T4; -50 to 75°C (-58 to 167°F), T5; -50 to 80°C (-58 to 176°F), T6; -50 to 75°C (-58 to 167°F) Max. process Temp. for gas-proof (Tp): T4; 120°C (248°F), T5; 100°C (212°F), T6; 85°C (185°F) Max. surface Temp. for dust-proof: T85°C (Tamb: -30 to 75°C, Tp: 85°C) ^{*2}	KF22
	ATEX Intrinsically safe Approval *1 Applicable Standard: EN 60079-0:2009, EN 60079-11:2007, EN 60079:2012, EN 60079-26:2007, EN 61241-11:2006 Certificate: DEKRA 11ATEX0228 X II 1G, 2D Ex ia IIC T4 Ga, Ex ia IIIC T85°C T100°C T120°C Db Degree of protection: IP66/IP67 Amb. Temp. (Tamb) for EPL Ga: -50 to 60°C (-58 to 140°F) Maximum Process Temp. (Tp) for EPL Ga:120°C Electrical data: UI=30 V, II=200 mA, PI=0.9 W, CI=27.6 nF, LI=0 μH Amb. Temp. for EPL Db: -30 to 60°C *2 Max. surface Temp. for EPL Db: T85°C (Tp: 80°C), T100°C (Tp: 100°C), T120°C (Tp: 120°C)	KS21
	Combined KF22, KS21 and ATEX Intrinsically safe Ex ic ^{*1} [ATEX Intrinsically safe Ex ic] Applicable Standard: EN 60079-0:2009, EN 60079-0:2012, EN 60079-11:2012 II 3G Ex ic IIC T4 Gc, Amb. Temp.: –30 to 60°C (–22 to 140°F) ^{*2} Ui=30 V, Ci=27.6 nF, Li=0 μH	KU22

<<Contents>> <<Index>>

Item	Description	Code
Canadian Standards Association (CSA)	CSA Explosionproof Approval ^{*1} Certificate: 2014354 Applicable Standard: C22.2 No.0, C22.2 No.0.4, C22.2 No.0.5, C22.2 No.25, C22.2 No.30, C22.2 No.94, C22.2 No.60079-0, C22.2 No.60079-1, C22.2 No.61010-1 Explosion-proof for Class I, Groups B, C and D. Dustignition-proof for Class II/III, Groups E, F and G. When installed in Division 2, "SEAL NOT REQUIRED" Enclosure: NEMA TYPE 4X, Temp. Code: T6T4 Ex d IIC T6T4 Enclosure: IP66/IP67 Max.Process Temp.: T4;120°C(248°F), T5;100°C(212°F), T6; 85°C(185°F) Amb.Temp.: –50 to 75°C(–58 to 167°F) for T4, –50 to 80°C(–58 to 176°F) for T5, –50 to 75°C(–58 to 167°F) for T6 ^{*2} Process Sealing Certification Dual Seal Certification Dual Seal Certified by CSA to the requirement of ANSI/ISA 12.27.01 No additional sealing required Primary seal failure annunciation: at the zero adjustment screw	CF1
	CSA Intrinsically safe Approval ^{*1} Certificate: 1606623 [For CSA C22.2] Applicable Standard: C22.2 No.0, C22.2 No.0.4, C22.2 No.25, C22.2 No.94, C22.2 No.157, C22.2 No.213, C22.2 No.61010-1, C22.2 No.60079-0 Intrinsically Safe for Class I, Division 1, Groups A, B, C & D, Class II, Division 1, Groups E, F & G, Class III, Division 1, Nonincendive for Class I, Division 2, Groups A, B, C & D, Class II, Division 2, Groups F & G, Class III, Division 1 Enclosure: NEMA TYPE 4X, Temp. Code: T4 Amb. Temp.: –50 to 60°C(–58 to 140°F) ^{*2} Electrical Parameters: [Intrinsically Safe] Vmax=30V, Imax=200mA, Pmax=0.9W, Ci=10nF, Li=0 μH [Nonincendive] Vmax=30V, Ci=10nF, Li=0 μH [For CSA E60079] Applicable Standard: CAN/CSA E60079-11, CAN/CSA E60079-15, IEC 60529:2001 Ex ia IIC T4, Ex nL IIC T4 Enclosure: IP66/IP67 Amb. Temp.: –50 to 60°C(–58 to 140°F) ^{*2} , Max. Process Temp.: 120°C(248°F) Electrical Parameters: [Ex ia] Ui=30V, Ii=200mA, Pi=0.9W, Ci=10nF, Li=0 μH [Ex nL] Ui=30V, Ci=10nF, Li=0 μH Process Sealing Certification Dual Seal Certified by CSA to the requirement of ANSI/ISA 12.27.01 No additional sealing required Primary seal failure annunciation: at the zero adjustment screw	CS1
	Combined CF1 and CS1 *1	CU1
IECEx	IECEx Flameproof Approval *1 Applicable Standard: IEC 60079-0:2004, IEC60079-1:2003 Certificate: IECEx CSA 07.0008 Flameproof for Zone 1, Ex d IIC T6T4 Enclosure: IP66/IP67 Max.Process Temp.: T4;120°C(248°F), T5;100°C(212°F), T6; 85°C(185°F) Amb.Temp.: -50 to 75°C(-58 to 167°F) for T4, -50 to 80°C(-58 to 176°F) for T5, -50 to 75°C(-58 to 167°F) for T6	SF2

Applicable for Electrical connection code 2, 4, 7, 9, C and D. Lower limit of ambient temperature is $-15^{\circ}C$ (5°F) when /HE is specified. *1: *2:

OPTIONAL SPECIFICATIONS

ltem		Description			Code	
High accuracy type		High accuracy				HAC
Painting	Color change	Amplifier cover only*2			P□	
		Amplifier cover and terminal co	ver, Munsell 7	.5 R4/14		PR
	Coating change	Anti-corrosion coating*1*2				X2
316 SST ext	terior parts	316 SST zero-adjustment screv	v and setscre	ws*3		HC
Fluoro-rubbe	er O-ring	All O-rings of amplifier housing.	Lower limit o	f ambient tem	perature: –15°C (5°F)	HE
Lightning pro	otector	Transmitter power supply voltage: 10.5 to 32 V DC (10.5 to 30 V DC for intrinsically safe type.) Allowable current: Max. 6000 A (1×40 µs), Repeating 1000 A (1×40 µs) 100 times Applicable Standards: IEC 61000-4-4, IEC 61000-4-5			Α	
Oil-prohibite	d use ^{*4}	Degrease cleansing treatment				K1
Oil-prohibite dehydrating		Degrease cleansing and dehyd	rating treatme	ent		K5
Calibration u	units ^{*5}	P calibration (psi unit)				D1
		bar calibration (bar unit)	(See Table for Span and Range Limits.)		D3	
		M calibration (kgf/cm ² unit)				D4
Long vent*6		Total length: 119 mm (standard: 34 mm); Total length when combining with option code K1 and K5: 130 mm. Material: 316 SST			U1	
Output limits operation*7	s and failure	Failure alarm down-scale: Output status at CPU failure and hardware error is -5%, 3.2mA DC or less.			C1	
		NAMUR NE43 Compliant	Failure alarm down-scale: Output status at CPU failure and hardware error is -5% , 3.2 mA DC or less.		C2	
				re alarm up-scale: Output status at CPU re and hardware error is 110%, 21.6 mA or more.		C3
Body option	*8 MI IV	Right side high pressure, without drain and vent plugs			N1	
Terminal		N1 and Process connection, based on IEC61518 with female thread on both sides of cover flange, with blind kidney flanges on back.			N2	
		N2, and Material certificate for cover flange, diaphragm, capsule body, and blind kidney flange			N3	
Wired tag plate		316 SST tag plate wired onto transmitter			N4	
Data configuration at factory ^{*9}		Data configuration for HART communication type Software damping, Descriptor, Message		СА		
		Data configuration for BRAIN communication type Software damping			СВ	
Material certificate ^{*10}		Cover flange *11			M01	
		Cover flange, Process connector *12			M11	
Pressure test/ Leak test certificate ^{*13}		Test Pressure: 50 kPa (7.25 psi)		Nitrogen(N2) Gas ^{*14} Retention time: one minute	Т04

*1: Not applicable with color change option.

Not applicable for amplifier housing code 2 and 3. 316 or 316L SST. The specification is included in amplifier housing code 2.

*2: *3: *4: *5: Applicable for Wetted parts material code S.

The unit of MWP (Max. working pressure) on the name plate of a housing is the same unit as specified by option codes D1, D3, and D4.

*6:

*7:

Applicable for vertical impulse piping type (Installation code 7) and Wetted parts material code S. Applicable for output signal codes D and J. The hardware error indicates faulty amplifier or capsule. Applicable for wetted parts material code S; process connection codes 3, 4, and 5; installation code 9; and mounting *8: bracket code N. Process connection faces on the other side of zero adjustment screw.

Also see 'Ordering Information'. *9:

*10:

Material traceability certification, per EN 10204 3.1B. Applicable for process connections codes 0 and 5. *11:


*12: Applicable for process connections codes 1, 2, 3, and 4.

*13: *14: The unit on the certificate is always Pa unit regardless of selection of option code D1, D3 or D4.

Pure nitrogen gas is used for oil-prohibited use (option codes K1 and K5).


DIMENSIONS

Unit: mm (approx.inch)



• Vertical Impulse Piping Type (INSTALLATION CODE '7')

• Horizontal Impulse Piping Type (INSTALLATION CODE '9') (For CODE '8', refer to the notes below.)




*1: When installation code 8 is selected, high and low pressure side on above figure are reversed. (i.e. High pressure side is on the right side.)

*2: When option code K1, K2, K5 or K6 is selected, add 15 mm (0.59 inch) to the value in the figure.

*3: When option code K1, K2, K5 or K6 is selected, add 30 mm (1.18 inch) to the value in the figure.


Unit: mm (approx.inch)



• Universal Flange (INSTALLATION CODE 'U')

*1: When Option code K1, K2, K5, or K6 is selected, add 30 mm (1.18 inch) to the value.

• Terminal Configuration



• Terminal Wiring

SUPPLY +	Power supply and output terminal
CHECK _	External indicator (ammeter) terminal*1*2
<u>+</u>	Ground terminal

*1: When using an external indicator or check meter, the internal resistance must be 10Ω or less.

*2: Not available for fieldbus and PROFIBUS communication types.

F06E.ai

< Ordering Information > "\ordering"

Specify the following when ordering

- 1. Model, suffix codes, and option codes
- 2. Calibration range and units
 - Calibration range can be specified with range value specifications up to 5 digits (excluding any decimal point) for low or high range limits within the range of -32000 to 32000. When reverse range is designated, specify Lower Range Value(LRV) as greater than Upper Range Value(URV). When square root output mode is specified, LRV must be "0 (zero) ".
 - Specify only one unit from the table, 'Factory setting.'
- Select linear or square root for output mode and display mode.

Note: If not specified, the instrument is shipped set for linear mode.

- Display scale and units (for transmitters equipped with the integral indicator only) Specify either 0 to 100 % or 'Range and Unit' for engineering units scale: Scale range can be specified with range limit specifications up to 5 digits (excluding any decimal point) for low or high range limits within the range of -32000 to 32000. Unit display consists of 6-digit, therefore, if the specified scaling unit excluding '/' is longer than 6-characters , the first 6 characters will be displayed on the unit display.
 HART PROTOCOL
- When output signal code is "J", specify the HART protocol revision "5" or "7".
- TAG NO (if required) Specified characters (up to 16 characters) are engraved on the stainless steel tag plate fixed on the housing.
- 7. SOFTWARE TAG (for HART only. if required) Specified characters (up to 32 characters) are set as "Tag" (the first 8 characters) and "Long tag"*1 (32 characters) in the amplifier memory. Use alphanumeric capital letters. When the "SOFTWARE TAG" is not specified, specified "TAG NO" is set as "Tag" (the first 8 characters) and "Long tag"*1 (16 characters) in the amplifier memory.
- *1: applicable only when HART 7 is selected.
- Other factory configurations (if required) Specifying option code CA or CB will allow further configuration at factory. Following are configurable items and setting range.
 - [/CA : For HART communication type]
 - 1) Descriptor (up to 16 characters)
 - 2) Message (up to 30 characters)
 - 3) Software damping in second (0.00 to 100.00)
 - [/CB : For BRAIN communication type]
 - 1) Software damping in second (0.00 to 100.00)

All Rights Reserved. Copyright © 2012, Yokogawa Electric Corporation Subject to change without notice.

< Factory Setting > "0"

Tag number	As specified in order
Software damping *1	'2.00 s' or as specified in order
Output mode	'Linear' unless otherwise specified in order
Calibration range lower range value	As specified in order
Calibration range upper range value	As specified in order
Calibration range unit	Selected from mmH ₂ O, mmH ₂ O(68°F), mmAq ^{*2} , mmWG ^{*2} , mmHg, Pa, hPa ^{*2} , kPa, MPa, mbar, bar, gf/cm ² , kgf/cm ² , inH ₂ O, inH ₂ O(68°F), inHg, ftH ₂ O, ftH ₂ O(68°F) or psi. (Only one unit can be specified.)
Display setting	Designated differential pressure value specified in order. (% or user scaled value.) Display mode 'Linear' or 'Square root' is also as specified in order.

- *1: To specify these items at factory, option code CA or CB is required.
- *2: Not available for HART protocol type.

< Material Cross Reference >

ASTM	JIS
316	SUS316
F316	SUSF316
316L	SUS316L
F316L	SUSF316L
304	SUS304
F304	SUSF304
660	SUH660
B7	SNB7
CF-8M	SCS14A